

別紙

## 分析項目

	水温	pH	TS (蒸発残 留物)	有機 物率	SS	BOD	COD	塩素 イオン	アンモニ ア態窒素	亜硝 酸態 窒素	硝酸 態窒 素	全窒 素	全りん	大腸 菌数	ノルマルヘキサン 抽出物質		水分	アンモ ニア	硫化 水素
															鉍物 類	動植 物油 脂類			
【水質検査】																			
1 搬入し尿	1	1	1		1	1	1	1	1			1							
2 搬入浄化槽汚泥	1	1	1		1	1	1	1	1			1							
3 投入し尿	1	1	1		1	1	1	1	1			1							
4 投入浄化槽汚泥	1	1	1		1	1	1	1	1			1							
5 希釈水	1	1			1	1	1	1				1							
6 圧送水(3本)	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3			
7 循環水	1	1			1	1	1	1				1							
8 油脂分離装置供給浄化槽汚泥	1	1			1														
9 油脂分離装置分離液	1	1			1														
10 油脂分離装置脱水汚泥																	1		
11 脱水し渣(2本)																	2		
【臭気測定】																			
1 高中濃度(3本)																		3	3
2 低濃度(3本)																		3	3
件体数	11	11	7	3	11	9	9	9	7	3	3	9	3	3	3	3	3	6	6