

願成就温泉施設の「温泉昇温マルチヒートポンプ」月別電力使用量の推計資料

【電気使用量】

	1月末	2月末	3月末	4月末	5月末	6月末	7月末	8月末	9月末	10月末	11月末	12月末	年間(想定)	
①施設総合計	77,133.0	73,654.0	74,992.0	60,698.0	59,541.0	53,338.0	57,423.0	56,668.0	54,998.0	59,576.1	64,091.0	73,797.0	765,909.1	
横丁テナント1	38.9	25.5	34.7	39.6	17.1	41.9	41.1	38.6	44.0	37.7	17.9	65.5		
横丁テナント2	226.4	351.4	252.4	214.9	66.7	145.5	165.8	307.5	360.3	338.5	219.8	291.7		
横丁テナント3	49.3	54.3	63.5	105.8	52.1	104.7	75.3	99.0	118.8	105.6	64.9	91.2		
横丁テナント4	19.5		44.6	104.7	67.3	139.2	119.1	134.5	118.0	89.7	24.8			
横丁テナント5			4.3	16.5	5.9	13.3	14.8	19.4	21.3	17.7	0.5			
横丁テナント6	25.1	35.5	36.6	37.8	24.1	48.7	34.2	44.4	39.3	39.0	24.9	30.9		
横丁テナント7	9.6	10.1	13.5	13.4	20.9	41.2	21.3	28.0	25.3	26.4	17.9	22.5		
横丁テナント8					18.3	86.6	41.8	45.0	32.6	26.0	24.7	14.2		
横丁テナント9	20.5	24.5	35.7	51.3	13.6	0.7	7.5	16.6	16.9	13.4	6.3	15.6		
レストラン100V	99.3	143.8	160.5	175.0	94.7	214.2	179.8	156.4	145.0	153.6	180.8	161.2		
レストラン200V	286.9	425.5	313.7	246.7	137.9	329.9	450.4	340.1	230.1	245.4	388.8	329.0	3,724.4	
②テナント小計	775.5	1,070.6	959.5	1,005.7	518.6	1,165.9	1,151.1	1,229.5	1,151.6	1,093.0	971.3	1,021.8	12,114.1	
①-②(温泉施設)	76,357.5	72,583.4	74,032.5	59,692.3	59,022.4	52,172.1	56,271.9	55,438.5	53,846.4	58,483.1	63,119.7	72,775.2	753,795.0	月平均
ヒートポンプ使用 量推計(温泉施設 の71.4%:資料2)	54,519	51,825	52,859	42,620	42,142	37,251	40,178	39,583	38,446	41,757	45,067	51,961	538,208.0	44,851

【参考】

レストラン200V(空調施設)電気料金(円)	28,690	42,550	31,370	24,670	13,790	32,990	45,040	34,010	23,010	24,540	38,880	32,900	372,440
------------------------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------